



# NC 150SS - PLYWOOD

NOTE:


- 1.) LAPS IN VALLEYWALL ARE 12" MIN. NEW CASTLE APPROVED SEALANT IN ALL LAPS IN VALLEY. TWO ROWS OF SEALANT BETWEEN VALLEYWALL LAPS, 4" UP FROM LAP.
- 2.) LARGE ROOF AREAS MAY REQUIRE A LARGER GAP BETWEEN PANEL AND WALL TO ALLOW FOR STORM WATER RUN OFF.



- NEW CASTLE APPROVED TUBE SEALANT
- FASTENERS (BY OTHERS)
- NEW CASTLE APPROVED TUBE SEALANT
- REGLET FLASHING
- VALLEYWALL FLASHING
- NEW CASTLE UNDERLAYMENT
- SEAM SEALANT (3'-0" UP FROM RIB END)
- NEW CASTLE APPROVED TUBE SEALANT (FIELD APPLIED BETWEEN PANEL RIBS)
- NC 150SS PANEL
- FIELD CUT & HEM PANEL 180°
- NEW CASTLE UNDERLAYMENT
- OFFSET CLEAT FLASHING
- D.B. TAPE SEALANT
- #10 - 13 x 1" PHW (12" o.c.)
- PLYWOOD SUBSTRATE (1/2" MIN.)
- CRICKET BEYOND



OPTION 1



OPTION 2

## VALLEYWALL

SCALE: 3" = 1'-0"

